

Honeywell Genetron® Performax™ LT Refrigerant



Properties, Uses, Storage and Handling

Honeywell

Honeywell Genetron® Performax™ LT

Table of Contents

Introduction	3
Applications	3
Physical Properties	3
Specifications	4
Servicing Considerations	4
Materials Compatibility.....	4
Safety & Toxicity	4
Packaging	4
Pressure vs. Temperature (English Units & SI Units)	5
Storage and Handling	6
Bulk and Cylinder	6
Maintenance	6
Leak Detection	7
Retrofitting Existing Systems	7
Retrofit Procedures	7
Retrofit Checklist	10
Recycling and Reclamation.....	11
Environmental Considerations.....	11
Available Literature/Technical Assistance	11

INTRODUCTION

Honeywell Genetron® Performax™ LT (a ternary blend of HFC-32/HFC-125/HFC-134a), serves as a non-ozone depleting replacement for HCFC-22 in various commercial refrigeration applications, particularly in low-temperature applications.

Since Genetron Performax LT (R-407F) is a close match to HCFC-22, it also serves as a retrofit fluid in applications where HCFC-22 is used.

APPLICATIONS

Genetron Performax LT is well-suited as a replacement for HCFC-22 in low- and medium-temperature commercial refrigeration applications such as supermarket freezer cases, display cases, reach-in coolers, transport refrigeration, and ice machines. Genetron Performax LT is not a “drop-in” replacement. Lubricants such as mineral oil and alkylbenzene that have traditionally been used with R-22 are immiscible with Genetron Performax LT. Miscible synthetic lubricants such as polyol esters should be used to ensure adequate oil return.

Genetron Performax LT is a blend refrigerant. It is essential that systems be charged with liquid from the cylinder. Vapor charging Genetron Performax LT may result in the wrong refrigerant composition and could damage the system. A throttling valve should be used to control the flow of refrigerant to the suction side to ensure that a liquid slug does not enter the compressor. For more details about proper retrofitting procedures, see “Servicing Considerations” and “Retrofitting Existing Systems” in this brochure.

PHYSICAL PROPERTIES

Chemical Name	Difluoromethane/ Pentafluoroethane/ Tetrafluoroethane
Molecular Formula	CH ₂ F ₂ /CHF ₂ CF ₃ /CH ₂ FCF ₃
Appearance	Colorless
Molecular Weight	82.1

UNITS	ENGLISH	SI
Bubble Point Temperature	-50.9°F @ 1 Atm	-46.1°C @ 101.3 kPa
Dew Point Temperature	-39.4°F @ 1 Atm	-39.7°C @ 101.3 kPa
Bubble Point Pressure†	190.2 (Psia)	1311 (kPa)
Dew Point Pressure†	165.9 (Psia)	1144 (kPa)
Critical Temperature	180.8°F	82.6°C
Critical Pressure	689.5 (Psia)	4754 (kPa)
Critical Volume	0.0336 (ft³/lb)	0.0021 (m³/kg)
Critical Density	29.8 (lb/ft³)	477.37 (kg/m³)
Vapor Density	0.279 (lb/ft³) @ 1 Atm	4.465 (kg/m³) @101.3 kPa
Liquid Density†	69.73 (lb/ft³)	1117 (kg/m³)
Liquid Heat Capacity†	0.38 (Btu/lb °F)	1.57 (KJ/kg K)
Vapor Heat Capacity†	0.28 (Btu/lb °F)	1.18 (KJ/kg K)
Heat of Vaporization	110.66(Btu/lb) @ 1 Atm	257.21 (KJ/kg) @101.3 kPa
Liquid Thermal Conductivity†	0.052 (Btu/hr ft °F)	89.71 (mW/m²K)
Vapor Thermal Conductivity†	0.0084 (Btu/hr ft °F)	14.51 (mW/m²K)
Liquid Viscosity†	0.348 (lbm/ft hr)	143.99 (Pa sec)
Vapor Viscosity†	0.032 (lbm/ft hr)	13.20 a (Pa sec)
Flammability Limits in Air (vol%)	None *	
Ozone Depletion Potential (ODP)	0.0	
ASHRAE Safety Group Classification	A1/A1	

* Based on ASHRAE Standard 34 with match ignition.

† All data are at 77°F (25°C) unless otherwise noted.

SPECIFICATIONS

Assay (Min. Wt. % of HFC-32/125/134a):	99.7%
Moisture (Max. Wt. %):	0.0010
Non-Volatile Residue (Max. Vol. %):	0.01
Chloride (Max. Wt. %):	0.0001
Total Acidity (Max. mg KOH/gm):	0.0015
Non-condensibles in vapor phase (Max. Vol. %): 1.5	

SERVICING CONSIDERATIONS

Genetron® Performax™ LT is a ternary blend of HFC-32/HFC-125/HFC-134a. This product was developed to be used in low- and medium-temperature commercial refrigeration applications, especially for retrofitting existing HCFC-22 systems.

Unlike pure fluids and azeotropes, blends boil and condense at varying temperatures for a given pressure. The range over which the temperature varies is referred to as temperature glide. Genetron Performax LT has a moderate temperature glide between about 4°F and 11°F, depending upon pressure. When dealing with blends, pressure-temperature tables are presented with two pressures listed for each temperature: the dew pressure and the bubble pressure. The dew pressure is used for determining the system pressure when the refrigerant is in a saturated vapor or superheated condition (i.e., on the suction and discharge sides of the compressor). The bubble pressure is used for determining the system pressure when the refrigerant is in a saturated liquid or subcooled condition (i.e., at the inlet to the expansion valve or capillary tube).

Genetron Performax LT must be the only liquid charged into a system to ensure proper refrigerant composition and system performance. (See “Retrofit Procedures” for more information.)

MATERIALS COMPATIBILITY

Chlorinated Materials and Refrigerants

Honeywell does not recommend the use of chlorinated solvents to clean refrigeration systems or components.

Desiccants

Desiccant driers compatible with Genetron Performax LT are commercially available. Individual drier manufacturers should be contacted for specific recommendations.

Compatibility of Plastics and Elastomers

The following table summarizes expected materials compatibility data for Genetron Performax LT. It is based on test results for the individual refrigerant components and R-32/R-125/R-134a blends performed by Honeywell and other worldwide industry organizations.

This data should be used only as a guide to the compatibility of materials with Genetron Performax LT. When retrofitting existing systems to Genetron Performax LT, Honeywell recommends that service technicians consult with original equipment manufacturers for their approved replacement parts. Since there are many different grades and formulations of these materials, we recommend that compatibility testing be performed on the specific grade of materials under consideration when designing new systems. The rankings in the table should be used with caution since they are judgments based on limited samplings. Customers should consult with the manufacturer or conduct further independent testing.

SAFETY & TOXICITY

Honeywell recommends reading the MSDS before using Genetron Performax LT.

PACKAGING

Genetron Performax LT is available in a variety of containers. They include 25-lb disposable JUG™, 115-lb returnable cylinders and one ton (1,600 lbs.) returnable tanks. In addition, bulk shipments can be made in tank trailers and isotanks.

Materials Compatibility Genetron® Performax™ LT: Plastics/Elastomers

Ethylene-Propylene Diene Terpolymer	S
Ethylene-Propylene Copolymer	S
Chlorosulfonated Polyethylene	S
Chlorinated Polyethylene	D
Neoprene (Chloroprene)	S
Epichlorohydrin	D
Fluorinated Rubbers	U
Silicone	D
Polyurethane	D
Nitriles	D
H-NBR	D
Butyl Rubber	D
Polysulfide	S
Nylon	S
Polytetrafluoroethylene	S
PEEK	S
ABS	U
Polypropylene	D
Polyphenyl Sulfide	U
Polyethylene Terephthalate	D
Polysulfone	D
Polyimide	S
Polyetherimide	S
Polyphthalamide	D
Polyamideimide	S
Acetal	D
Phenolic	S

Pressure vs. Temperature

Temp °F	Bubble Pressure psig	Dew Pressure psig	Temp °C	Bubble Pressure bar-g	Dew Pressure bar-g
-40	4.9	* 0.4	-40	0.3	0.0
-35	7.5	1.9	-38	0.5	0.1
-30	10.4	4.2	-36	0.6	0.2
-25	13.6	6.8	-34	0.8	0.3
-20	17.1	9.7	-32	0.9	0.4
-15	20.9	12.9	-30	1.1	0.6
-10	25.1	16.4	-28	1.3	0.7
-5	29.6	20.2	-26	1.5	0.9
0	34.5	24.4	-24	1.7	1.1
5	39.8	28.9	-22	1.9	1.3
10	45.6	33.9	-20	2.1	1.4
15	51.8	39.3	-18	2.4	1.7
20	58.5	45.1	-16	2.6	1.9
25	65.6	51.4	-14	2.9	2.1
30	73.3	58.2	-12	3.2	2.4
35	81.6	65.5	-10	3.5	2.6
40	90.4	73.4	-8	3.8	2.9
45	99.7	81.8	-6	4.1	3.2
50	109.7	90.8	-4	4.5	3.5
55	120.4	100.5	-2	4.9	3.9
60	131.7	110.8	0	5.3	4.2
65	143.7	121.8	2	5.7	4.6
70	156.4	133.5	4	6.1	5.0
75	169.9	146.0	6	6.6	5.4
80	184.1	159.2	8	7.1	5.8
85	199.1	173.3	10	7.6	6.3
90	215.0	188.2	12	8.1	6.7
95	231.7	203.9	14	8.6	7.2
100	249.3	220.6	16	9.2	7.8
105	267.8	238.3	18	9.8	8.3
110	287.2	256.9	20	10.4	8.9
115	307.6	276.6	22	11.1	9.5
120	329.0	297.4	24	11.8	10.1
125	351.5	319.3	26	12.5	10.8
130	375.0	342.4	28	13.2	11.4
135	399.7	366.8	30	13.9	12.1
140	425.4	392.4	32	14.7	12.9
145	452.4	419.5	34	15.6	13.7
150	480.6	448.0	36	16.4	14.5
*inches of mercury vacuum			38	17.3	15.3
			40	18.2	16.2
			42	19.2	17.1
			44	20.1	18.0
			46	21.2	19.0
			48	22.2	20.0
			50	23.3	21.1
			52	24.4	22.2
			54	25.6	23.3
			56	26.8	24.5
			58	28.0	25.8
			60	29.3	27.1
			62	30.7	28.4
			64	32.0	29.8
			66	33.5	31.2
			68	34.9	32.7

STORAGE AND HANDLING

Bulk and Cylinder

Some special handling and storage procedures are required for Genetron® Performax™ LT to minimize or prevent liquid compositional changes, particularly those occurring during liquid level depletion or vapor leaks from the storage container. Because these procedures and/or systems are sometimes site specific for designed leak storage systems, contact a Honeywell Technical Service representative to discuss each application. Among the most important handling practices that must be followed for Genetron Performax LT is transfer of the refrigerant as liquid from one vessel to another. This practice will help minimize compositional changes in the liquid phase and, as a result, provide a more consistent product. Genetron Performax LT cylinders must be kept in a cool, dry and properly ventilated storage area away from heat, flames, corrosive chemicals, fumes, explosives—and be otherwise protected from damage. Under no circumstances should anything be put into an empty cylinder. Once empty, properly close the cylinder valve and replace the valve cap. Return empty cylinders to your Genetron Wholesaler. Disposable JUG™ should be discarded in an environmentally safe manner in accordance with all applicable laws and regulations.

Cylinders of Genetron Performax LT should be kept out of direct sunlight, especially in warm weather. Liquid Genetron Performax LT expands significantly when heated, reducing the amount of vapor space left in the cylinder. Once the cylinder becomes liquid-full, any further rise in temperature can cause it to burst, **potentially resulting in severe personal injury. Never allow a cylinder to get warmer than 125°F (52°C).** Always store cylinders above dirt or damp floors to prevent rusting, using a platform or parallel rails. **Secure cylinders in place by means of a rack, chain or rope to prevent them from tipping, falling, rolling or accidentally striking each other or any other object.** If the cylinder valve is broken off, rapid escape of the high pressure contents will propel the cylinder, which could potentially result in serious injury. Keep cylinder caps in place until the cylinder is in use. The storage area should be away from corrosive chemicals or fumes to avoid damaging effects on the cylinder and threaded areas of the valve. Follow similar precautions for bulk storage and transport systems, ensuring that proper design and operation satisfies the required pressure rating and also avoids external corrosive conditions, over-heating or over-filling.

Any evidence of a leak, whether visually or by a leak detector (see leak detection section), should be

corrected immediately by either stopping the leak or transferring all products from the leaking container into a secure container to allow for repairs. Only attempt transfer and repair if these actions can be performed safely. If there are concerns or questions, contact Genetron Refrigerants Technical Service for assistance.

Maintenance

A thorough pre-job review must be done to determine respiratory protection requirements, as well as any other safety equipment needed. Maintenance in areas where Genetron Performax LT has accumulated should be performed only after confirming that work area concentrations are below the permissible exposure level (PEL). This may be determined using a vapor-in-air analyzer capable of measuring the amount of airborne Genetron Performax LT. These vapors are heavier than air and can accumulate at floor level. When vapor concentrations are above the PEL, the area should be ventilated to reduce the vapor concentration to below the PEL before entry. Ventilate the area using fans and other air movers as necessary. If entry must be made to areas where vapor concentrations are above the PEL, appropriate respiratory protection should be used.

Federal occupational health and safety agencies often have legal requirements and guidelines for proper selection and use of respiratory protection. It is often the responsibility of the employer to ensure the safety of the employees performing the maintenance. Be sure to comply with applicable laws and guidelines for proper selection and use of respiratory protection. If the airborne concentration of refrigerant is unknown or at a particular threshold, the law may require the use of supplied air respirators. Particular work team and work zone entry procedures may also apply.

Vessels, containers, transfer lines, pumps and other equipment should not be exposed to high-temperature sources (such as welding, brazing and open flames) until they have been thoroughly cleaned and found free of vapors. Exposure to these circumstances can cause fire, explosion and decomposition of refrigerant. This may result in the formation of toxic or corrosive compounds. Potential sources for further vapor releases should also be eliminated if possible. When possible, maintenance or cleaning of equipment should be performed without entering the vessel. A tank or storage vessel may be a confined space. These spaces may have a configuration that can hinder activities and/or expose personnel to the risk of physical injury from entrapment, engulfment, or hazardous atmospheres. Depending on conditions and applicable regulations, a permit may be required to enter such vessels. If a tank must be entered, personnel should be required to use a formal tank entry procedure based on recognized

safety principles and comply with all applicable regulations. The procedure would provide guidance for critical items such as but not limited to respiratory protection, safety equipment, work practice, and communication. Among the possible requirements of these procedures is the use of a fully qualified work team and placement of a confined space entry permit at the job site.

LEAK DETECTION

Use leak detectors for pinpointing specific leaks or for monitoring an entire room on a continual basis. Leak detectors are important for refrigerant conservation, equipment protection and performance, reduction of emissions and protection of those coming in contact with the system. Leak testing should not be performed with mixtures of air and Genetron® Performax™ LT. Make sure the leak detector is capable of detecting Genetron Performax LT before using.

Types of Leak Detectors

There are two types of leak detectors – leak pinpointers and area monitors. Before selecting either type, several equipment factors should be considered, including detection limits, sensitivity and selectivity. With selectivity, there are three categories of leak detectors: non-selective, halogen selective or compound selective. In general, the complexity and cost of a leak detector increases as its specificity increases. Fluorescent dyes approved for use by the equipment manufacturer can be added to systems to help pinpoint leaks.

RETROFITTING EXISTING SYSTEMS

As the industry moves away from the use of HCFCs, refrigerant service personnel will play a key role in the transition to alternatives through retrofitting. Honeywell has prepared the following guidelines to help service technicians better understand the various technical and operational aspects of performing retrofits on refrigeration systems using Genetron Performax LT. Although the information can be helpful as a general guide, it should not be used as a substitute for the equipment manufacturer's specific recommendations. For this reason, Honeywell recommends contacting the equipment manufacturer for detailed information on retrofitting the specific equipment under consideration. Always refer to the Material Safety Data Sheet (MSDS) for safety information on the use of Genetron Performax LT.

Retrofit

Genetron Performax LT can be used successfully as a retrofit fluid but may require some system modifications such as changing the lubricant. Mineral oils and alkylbenzene lubricants, which have been used traditionally with HCFC-22, are immiscible with Genetron Performax LT and must be replaced with miscible lubricants such as polyol esters. Consult the original equipment manufacturer for the recommended lubricants.

RETROFIT PROCEDURES

1. Record Baseline Data

Prior to retrofitting, it is desirable to record system performance data to establish the normal operating conditions for the equipment. Data should include temperature and pressure measurements throughout the system, including the evaporator, compressor suction and discharge, condenser and expansion device. These measurements will be useful when adjusting the system to Genetron Performax LT during the retrofit.

2. Return Lubricant

Run each circuit through a defrost cycle to return as much lubricant as possible to the condensing unit. This aids in consolidating lubricant that may have been in circulation throughout the system and makes it easier to isolate for later removal.

3. Isolate HCFC-22 Charge

The HCFC-22 charge should be isolated from the rest of the system by pumping it down into the condensing unit or receiver. If no receiver is present, the refrigerant must be removed from the system using a certified recovery machine capable of meeting or exceeding the required levels of evacuation as specified by the U.S. EPA. The charge must be collected in a recovery cylinder.

4. Record the Amount of HCFC-22 Recovered

It is important to have a record of the amount of HCFC-22 recovered since this will be the basis for determining the Genetron Performax LT charge amount in Step 16.

5. Choose Compressor Lubricant

Mineral oil or alkylbenzenes are typically used as the lubricants for HCFC-22 compressors. A miscible lubricant such as a polyol ester is commonly used. Honeywell recommends using a lubricant approved by the compressor manufacturer. Differences among the various lubricants make it difficult to assume

they are interchangeable. Check with the compressor manufacturer for the approved viscosity grade and brand of lubricant for the compressor in the system being retrofitted.

6. Drain the Lubricant

Since many small hermetic compressors do not have oil drains, it may be necessary to remove the compressor from the system to drain the lubricant. The suction line of the compressor is the best point to drain the lubricant. Using this procedure, it is possible to drain nearly 95 percent of the lubricant. Small hand-operated pumps are available which permit insertion of a tube into the compressor access port for removal of the mineral oil without removing the compressor from the system. Remember that most of the oil must be removed from the system before adding the replacement lubricant. For larger systems, the oil should be drained from multiple points in the system. Particular attention should be paid to low spots around the evaporator where lubricant often collects. The oil also should be drained from oil separators and/or suction accumulators.

7. Measuring Existing Lubricant

Measure and record the volume of lubricant removed from the system. Compare this amount with the amount recommended by the manufacturer to ensure that the majority of lubricant has been removed. This volume also will be used as a guide to determine the amount of lubricant to add in step 9.

8. Change Lubricant Filters if Present

It is good practice to change lubricant filters if the system is so equipped. New filters will help to protect the system.

9. Recharge Compressor with a Miscible Lubricant

Add to the compressor the same volume of miscible lubricant, for example, polyol ester, as the volume of the mineral oil drained in step 6.

10. Evaluate Need for Multiple Lubricant Flushes

Past retrofit practice would have been to recharge the HCFC-22 and run for at least 24 hours to return residual mineral oil to the compressor(s) and oil management system. Typically, 5% residual mineral oil was targeted. Recent field experience suggests that a single oil change may be adequate prior to addition of Genetron® Performax™ LT. Consult Honeywell Refrigerants Technical Service for guidance. (When only one oil change is needed, go to Step 11 below. If R-22 is to be circulated with the

new lubricant to further reduce the mineral oil residual, continue with Step 10 as below.)

If the system R-22 charge was pumped into the receiver, the balance of the system should be evacuated and then the receiver valves opened. If the original charge was collected in a recovery cylinder, the system should be evacuated and then recharged with the original HCFC-22. It may be necessary to “top off” the refrigerant charge to compensate for the small amount lost in draining the lubricant.

Run the Compressor

Run the compressor with the new lubricant and the HCFC-22 for at least 5 hours for smaller systems and 24 hours for larger ones. Next, drain the lubricant and recharge with a new charge of lubricant. Check the lubricant that was drained to see if the residual mineral oil content is below 5%. Test kits are available from several lubricant suppliers that check for residual mineral oil content. Generally, it will require about one to three charges to get the mineral oil content down to the acceptable level.

Continue to Flush the System

Repeat steps 8 and 9 until the residual mineral oil content is below 5%. The lubricant that was removed from the compressors in the flushing procedure must be disposed of properly.

11. Evaluate the Expansion Device

Honeywell recommends consulting with the equipment manufacturer before retrofitting. Most HCFC-22 systems with either expansion valves or capillary tubes will operate satisfactorily with Genetron Performax LT.

12. Replace Sealing Devices

Evaluate and replace all elastomeric seals and gaskets including receiver float, alarm and level control gaskets. HFC refrigerants typically do not swell the “R-22 service” elastomers to the same extent. Sealing devices may also have a certain amount of heat set and/or compression set that can affect their resiliency.

13. Replace the Filter Drier

Following system maintenance, a recommended service practice is to replace the filter drier. There are two types of filter driers commonly used in refrigeration equipment — loose-fill and solid-core. Contact your wholesaler to obtain a replacement filter drier compatible with Genetron Performax LT.

14. Check for System Leaks

Check the system for leaks using normal service practices.

15. Reconnect the System and Evacuate

Use normal service practices to reconnect and evacuate the system. To remove air and other noncondensibles, Honeywell recommends evacuating the system to a full vacuum of 1000 microns or less from both sides of the system. Attempting to evacuate a system with the pump connected to only the low side of the system will not adequately remove moisture and non-condensibles such as air. Use a good electronic gauge to measure the vacuum. An accurate reading cannot be made with a refrigeration gauge.

16. Charge System with Genetron® Performax™ LT

When charging the system with Genetron Performax LT, it is important to remember that this product is a blend and not an azeotrope. For this reason, special charging procedures are required to ensure optimal system performance. It is essential when using Genetron Performax LT that the system be liquid-charged by removing only liquid from the cylinder. Never charge the system with vapor from a Genetron Performax LT cylinder. Vapor-charging Genetron Performax LT may result in the wrong refrigerant composition and could damage the system. A throttling valve should be used to control the flow of refrigerant to the suction side to prevent liquid slugs from entering the compressor. **NOTE: To prevent compressor damage, do not charge liquid into the suction line of the unit.**

Honeywell recommends initially charging the system with 85 percent by weight of the original HCFC-22 charge. For example, if the original HCFC-22 charge was 10 pounds, initially charge 8.5 pounds of Genetron Performax LT. If the original HCFC-22 charge was 1000 grams, initially charge 850 grams of Genetron Performax LT.

17. Check System Operation

Start the system and let conditions stabilize. Compressor suction pressures for the Genetron Performax LT after stabilization should be similar to that of normal system operating pressure with HCFC-22 for most applications. Compressor discharge pressures typically will be higher (about 20%) than normal system operation with HCFC-22. The condenser fan and ambient controls may require adjustment. It may be necessary to reset the high pressure cutout to compensate for the higher discharge pressures of the Genetron Performax LT system. This procedure should be done carefully to avoid exceeding the recommended operating limits of the compressor and other system components.

18. Adjust Refrigerant Charge, if Necessary

Systems being charged with Genetron Performax LT require a smaller charge size than those using HCFC-22. The charge typically will be about 95 percent by weight of the original HCFC-22 charge. If the system is undercharged, add additional Genetron Performax LT in increments of 5 percent by weight of the original HCFC-22 charge. For example, if the original charge was 10 pounds, charge in increments of 0.5 pounds. If the original charge was 1000 grams, charge in increments of 50 grams. Continue until desired operating conditions are achieved. Use dew-point pressure as a reference in determining the appropriate saturated temperature for a superheat setting. To determine the saturated temperature for a subcooling calculation, use bubble-point pressure.

To avoid overcharging, it is best to charge the system by first measuring the operating conditions (including discharge and suction pressures, suction line temperature, compressor amps, super heat) before using the liquid-level sight glass as a guide.

19. Label Components and System

After retrofitting the system with Genetron Performax LT, label the system components to identify the type of refrigerant (Genetron Performax LT) and specify type of lubricant (by brand name) and viscosity grade in the system. This will help ensure that the proper refrigerant and lubricant will be used to service the equipment in the future.

20. Monitor the System

Observe system operating parameters. Check the condition of the lubricant. It may become necessary to change lubricant filters or suction filters since the retrofit activity and the solvency of synthetic lubricants can return material to the condensing unit.

RETROFIT CHECKLIST FOR HONEYWELL GENETRON® PERFORMAX™ LT



Retrofit Checklist

- ☐ 1. Record baseline data on original system performance (amp draw, suction pressure, discharge pressure, superheat, sub cooling).
- ☐ 2. Run each circuit through a defrost cycle to return as much lubricant as possible to the condensing unit.
- ☐ 3. Recover HCFC-22 refrigerant charge using appropriate recovery equipment.
- ☐ 4. Record the amount of HCFC recovered.
- ☐ 5. Choose compressor lubricant. Consult compressor manufacturer for lubricant recommendations. Note that lubricants from various manufacturers must not be mixed.
- ☐ 6. Drain the existing lubricant from the compressors, separators and oil reservoirs.
- ☐ 7. Measure amount of lubricant removed.
- ☐ 8. Change lubricant filters if present.
- ☐ 9. Recharge the system with synthetic lubricant, use the same amount that was removed.
- ☐ 10. Traditionally at this point the R-22 would be returned to the system and the system run for at least 24 hours to return as much of the residual mineral oil in the system to the compressors and oil management system. Typically an acceptable residual mineral oil content of 5% was the target. Recent field data suggests the possibility of a successful retrofit with only one oil change performed before the addition of Genetron Performax LT. Consult Honeywell Refrigerants Technical Service for guidance.
- ☐ 11. Evaluate the expansion devices; consult the valve manufacturers for recommendations. No change is necessary in most cases.
- ☐ 12. Evaluate and replace all elastomeric seals including receiver float, alarm and level control gaskets.
- ☐ 13. Replace filter driers and suction filters.
- ☐ 14. Leak check the system and make repairs as required.
- ☐ 15. Evacuate the system.
- ☐ 16. Charge the system with Genetron Performax LT. Remove only liquid from the charging cylinder. Initial charge should be approximately 85% of the R-22 charge by weight. Record the amount of refrigerant charged.
- ☐ 17. Check system operation and operating controls. The discharge pressure of LT is slightly higher and condenser fan and ambient controls may require adjustment.
- ☐ 18. Adjust refrigerant charge if necessary, final charge should not exceed 95% of the original R-22 charge.
- ☐ 19. Label components and the system with the type of refrigerant and lubricant.
- ☐ 20. Monitor the system and pay particular attention to the condition of the lubricant. Change lubricant filters or suction filters if necessary. The retrofit activity and synthetic lubricant acting as a solvent may return material to the condensing unit.

RECYCLING AND RECLAMATION

The Clean Air Act Amendments of 1990 require mandatory recycling and reclamation of Genetron® Performax™ LT during maintenance, service or repair of air-conditioning and refrigeration equipment. Your Genetron Wholesaler offers a refrigeration reclamation program for Genetron Performax LT.

For the name of your nearest Genetron Performax LT Wholesaler, call 1-800-631-8138.

ENVIRONMENTAL CONSIDERATIONS

Genetron Performax LT is a halogenated hydrocarbon. Treatment or disposal of wastes generated by use of this product may require special consideration, depending on the nature of the wastes and the means of discharge, treatment or disposal. For more information, refer to the Material Safety Data Sheet (MSDS).

If discarded unused, Genetron Performax LT is not considered a “hazardous waste” by the Resource Conservation Recovery Act (RCRA). Because Genetron Performax LT is considered to have minimum biodegradability, care should be taken to avoid releases to the environment.

The disposal of Genetron Performax LT may be subject to federal, state and local regulations. Users should conduct disposal operations in compliance with applicable federal, state and local laws and regulations. Appropriate regulatory agencies also should be consulted before discharging or disposing of waste materials.

AVAILABLE LITERATURE/ TECHNICAL ASSISTANCE

Honeywell has a wide range of literature available for all of its environmentally safer Genetron products, covering such topics as reclamation, retrofitting guidelines, product specifications and technical properties. Much of this information is available online at **www.genetron.com**. In addition, Honeywell technical specialists are available to assist you in all phases of using Genetron Performax LT – especially retrofitting, handling and storage and applications assistance. For further information, please write us at:

Honeywell
Genetron Refrigerants
P.O. Box 1053
Morristown, NJ 07962-1053
Or call us at 1-800-631-8138

Worldwide Sales Offices

United States

Honeywell International
101 Columbia Road
Morristown, NJ 07962-1053
Phone: 800-631-8138
Fax: 973-455-6395

Latin America/Caribbean

Honeywell Chemicals Mexico
Constituyentes 900
Col. Lomas Atlas
C.P. 950, Mexico DF
Mexico
Phone: 52-55-5549-0303
Fax: 52-55-5544-9803

Canada

Honeywell Asca. Inc.
3333 Unity Drive
Mississauga, Ontario
L5L 3S6
Phone: 905-608-6325
Fax: 905-608-6327

Asia-Pacific

Honeywell (China) Co., Ltd.
No 430, Li Bing Road
Zhang Jiang Hi-Tech Park
Pudong New Area, Shanghai 201203
China
Phone: 86-21-2894-2000
Fax: 86-21-5855-2719

Honeywell Japan Inc.
New Pier Takeshiba
South Tower Building, 20th Floor
1-16-1 Kaigan, Minato-ku,
Tokyo 050022, Japan
Phone: 81-3-6730-7000
Fax: 81-3-6730-7221

Honeywell Chemicals, Korea
6F Janghakjaedan, B/D 44-1
Bangpo-Dong, Seocho-Ku
Seoul 137040, Korea
Phone: 8-22-595-0204
Fax: 8-22-595-4964

Honeywell Specialty Chemicals
(Singapore) Pte. Ltd.
17 Changi Business Park Central 1
Honeywell Building
Singapore 486073
Phone: 65-6355-2828
Fax: 65-6783-2947

Honeywell International
71 Queens Road, Ground Floor
Melbourne, Victoria 3004
Australia
Phone: 61-3-9529-1411
Fax: 61-3-9510-9837

Northern and Central Europe

Honeywell Belgium NV
Haasrode Research Park
Grauwmeer 1
3001 Heverlee
Belgium
Phone: 32-16-391-212
Fax: 32-16-391-371

Southern Europe, Middle East and Africa

Honeywell Fluorine Products Italia Srl
V. Le Milanofiori El
20090 Assago - MI - Italia
Phone: 0039-02-89259601
Fax: 0039-02-57500815

Customer Service

To place an order from anywhere in the Continental United States, Hawaii and the Caribbean:

Phone: 800-522-8001
Fax: 800-458-9073

Canada:
Phone: 800-553-9749
Fax: 800-553-9750

Northern and Central Europe
Phone: +32-16-391-209
Phone: +32-16-391-216
Fax: +32-16-391-235

Southern Europe, Middle East and Africa
Phone: +39-02-9379-6777
ext. 24 / 25 and 26
Fax: +39-02-9379-6761

Outside these areas:
Phone: 1-973-455-6300
Fax: 1-973-455-2763



RESPONSIBLE CARE®
OUR COMMITMENT TO SUSTAINABILITY

Disclaimer

The information provided herein are believed to be accurate and reliable, but are presented without guarantee or warranty of any kind, express or implied. User assumes all risk and liability for use of the information and results obtained. Statements or suggestions concerning possible use of materials and processes are made without representation or warranty that any such use is free of patent infringement, and are not recommendations to infringe any patent. The user should not assume that all safety measures are indicated herein, or that other measures may not be required.

Genetron is a registered trademark of Honeywell International Inc.
Performax is a trademark of Honeywell International Inc.
JUG is a trademark of Honeywell International Inc.
February 2012
Printed in U.S.A.
© 2013 Honeywell International Inc. All rights reserved.

Honeywell Genetron Refrigerants

101 Columbia Road
Morristown, NJ 07962-1053
Phone: 1-800-631-8138

www.honeywell-refrigerants.com
www.genetronperformaxlt.com

Honeywell